



GMFZC.EX5323 Self-contained Automatic Extinguisher Units

[Page Bottom](#)

Self-contained Automatic Extinguisher Units

[See General Information for Self-contained Automatic Extinguisher Units](#)**FIRETRACE USA L L C**

EX5323

SUITE 2

8435 N 90TH ST

SCOTTSDALE, AZ 85258 USA

Fire extinguisher units containing ABC dry chemical powder

Model	Agent Capacity, lb	Nozzles Per Discharge Port	Max Protection Area, ft ²	Max Hazard Length, ft (any side)	Maximum Ceiling Height, ft	Rating	Date of Installation Manual (Date of Supplement)
940202	2.5	1 or 2	31.36	5.58	6.0	B:C	2011-05-31 Rev 3 (p/n 800010)
940502	5.0	1 or 2	42.25	6.50	9.0	B:C	2011-05-31 Rev 3 (p/n 800010)
941002	10.0	1 or 2	84.50	6.50	9.0	B:C	2011-05-31 Rev 3 (p/n 800010)
942002	20.0	1	84.50	6.50	9.0	B:C	2011-05-31 Rev 3 (p/n 800010)
942002	20.0	2	169.00	6.50	9.0	B:C	2011-05-31 Rev 3 (p/n 800010)

These units are intended for the following:

- A. Protection of Class B flammable liquid and Class C fires occurring within an enclosure.
- B. Protection where a free-burning fire may be expected. For total flooding applications, the hazard is to be surrounded by a fixed enclosure that enables the required dry chemical concentration to be built up and maintained for the required period of time to ensure the effective extinguishment of fire in combustible materials. The enclosure shall be reasonably tight and the unit shall employ a means of automatic closure of ventilation openings.
- C. Storage and use within the temperature range of 0 to 130°F.
- D. Operating Pressure of 195 psig.
- E. Intended for vertical (upright) installation only

[Last Updated](#) on 2012-09-26[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

Copyright © 2012 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2012 Underwriters Laboratories of Canada Inc."

An independent organization working for a safer world with integrity, precision and knowledge.

