



# Certificate of Compliance

## FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

<b>System Designation:</b>	Model IHP Pre-Engineered Automatic Indirect Carbon Dioxide Extinguisher Units
<b>System Type:</b>	Pre-Engineered Total Flooding System for the Protection of Class B Hazards
<b>Design, Installation, Operation, and Maintenance Manual:</b>	Design, Installation, Operation, and Maintenance Manual for Pre-Engineered Automatic Indirect Carbon Dioxide Extinguisher Units, 800024, Rev. 004, July 2016

*Approval Guide* Listing Category: Fixed Extinguishing Systems, Carbon Dioxide Systems, Carbon Dioxide Systems

Firetrace International LLC  
8435 N. 90th Street, Suite 2,  
Scottsdale AZ 85258  
USA

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):

<i>Approval Standards</i>	<i>Date</i>
<i>Class Number</i> 5420	April 2007

FM Approvals Listing Class: 5420

Re-Examination Project: 3039427  
Subsequent Revisions: 3058016

Approval Granted: July 24, 2013

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

A handwritten signature in dark ink, appearing to read 'J.E. Marquedant', written over a horizontal line.

James E. Marquedant  
Manager - Electrical Systems  
FM Approvals  
1151 Boston-Providence Turnpike,  
Norwood MA, 02062 USA

28 September 2016

\_\_\_\_\_  
Date



*Member of the FM Global Group*