



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

System Designation:	35 Bar Engineered Clean Agent Fire Suppression System Designed for use with 3M™ Novec™ 1230 Fire Protection Fluid
Flow Calculation Software:	VdS SCHADENVERHUTUNG FK-5-1-12 -Calculationprogram Version 7.5, Licensed to Firetrace USA, LCC, utilizing: <ul style="list-style-type: none">• Pipe Catalogue: FT Pipe - Schedule 40 - 1.0.0.rkl• Component Catalogue: FT Components 1.0.0.arm• Nozzle Catalogue: FT Nozzles - 1.0.2.noz
Design, Installation, Operation, Maintenance, Software, and Owner's Manuals:	Firetrace 35 bar Engineered Clean Agent Fire Suppression System Designed for use with 3M™ Novec™ 1230 Fire Protection Fluid Design, Installation, Operation, and Maintenance Manual, 000007-000, dated 06/30/2016

Approval Guide Listing Category: Fixed Extinguishing Systems, Clean Agent Fire Extinguishing Systems

Firetrace USA, LLC
8435 N 90th Street, Suite 2
Scottsdale AZ 85258
USA

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):

<i>Approval Standards</i>	<i>Date</i>
<i>Class Number</i>	
5600	April 2013


FM Approvals Listing Class: 5612

Original Approval Project Identification: 3044465
Subsequent Revisions: N/A

Approval Granted: 11 July 2016

To verify the availability of the Approved product, please refer to www.ApprovalGuide.com




James E. Marquedant
Manager - Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA 02062 USA

11 July 2016

Date