



**APPROVED**

# Certificate of Compliance

## FIXED EXTINGUISHING SYSTEMS, CLEAN AGENT EXTINGUISHERS, AUTOMATIC OR MANUAL-AUTOMATIC

This certificate is issued for the following product:

System Designation:	Models 940205, 940505, and 941005 Automatic Indirect Fire Detection and Extinguishing Systems
System Type:	Pre-Engineered for the Protection of Class B Hazards
Agent Identification:	3M™ NOVEC™ 1230
Design, Installation, Operation, and Maintenance Manual:	<i>Design, Installation, Operation, and Maintenance Manual for Pre-Engineered Automatic Indirect NOVEC™ 1230 Clean Agent Extinguisher Unit, P/N 800025, Rev 00, May 18, 2009</i>

**Approved for:** FIRETRACE INTERNATIONAL  
 15690 N. 83<sup>RD</sup> WAY, SUITE B  
 SCOTTSDALE, AZ  
 85260

FM Approvals confirms that the system has been found to comply with the following standard:

UL 2166 – Halocarbon Clean Agent Extinguishing System Units

Project Identifier: 3026082

Date of Approval: May 20, 2009

Richard B. Dunne

Manager – Hydraulics Group, FM Approvals



Member of the FM Global Group

5/20/09

Date